

PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

Environmental DustTrak™ Aerosol Monitor 854201-M1

Manufactured by:

TSI Incorporated

500 Cardigan Road
Shoreview
MN
USA

has been assessed by Sira Certification Service
And for the conditions stated on this certificate complies with:

**MCERTS Performance Standards for
Indicative Ambient Particulate Monitors,
Version 3, dated August 2015**

Certification Ranges :

PM₁₀ 0 to 10,000 µg/m³

Project No. : 70085194
Certificate No : Sira MC160316/02
Initial Certification : 02 December 2016
This Certificate issued : 19 December 2018
Renewal Date : 01 December 2021

Emily Alexander
Environmental Project Engineer

MCERTS is operated on behalf of the Environment Agency by

Sira Certification Service

Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
Tel: +44 (0)1244 670 900



*The MCERTS certificate consists of this document in its entirety.
For conditions of use, please consider all the information within.
This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certificate Contents

Approved Site Application.....	2
Basis of Certification	2
Product Certified.....	2
Certified Performance	3
Description.....	4
General Notes	4

Approved Site Application

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at www.mcerts.net

On the basis of these tests this certificate is valid when the instrument is used for urban air quality monitoring and similar applications.

The field test was conducted on a site representative of urban background particulate loading.

Basis of Certification

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

Bureau Veritas Report ref AGGX6339002/BV/2988, dated September 2016

Product Certified

The measuring system consists of the following parts:

- 854201-M1 or EDTPM10M Environmental DustTrak Aerosol Monitor
 - 8542-M Environmental DustTrak Photometer;
 - 854038 or 854030 Environmental Enclosure;
 - 854020 PM10 Impactor;
 - 854041 Heated Inlet Sample Conditioner and Omni Directional Inlet with Water Trap

This certificate applies to all instruments fitted with software version 3.5 (serial number 8543152503) onwards.

Certificate No : Sira MC160316/02
This Certificate issued : 19 December 2018

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certified Performance

Test	Result	MCERTS specification
Constancy of the sample volumetric flow	<3%	Remain constant within $\pm 3\%$ of rated value
Tightness of the sampling system	0%	Leakage not to exceed 2% of sampled volume
Intra-instrument uncertainty for the reference method	0.51 $\mu\text{g}/\text{m}^3$ Note 1	$\leq 5\mu\text{g}/\text{m}^3$
Intra-instrument uncertainty for the candidate method All data $\geq 30 \mu\text{g}/\text{m}^3$ $\leq 30 \mu\text{g}/\text{m}^3$	0.62 $\mu\text{g}/\text{m}^3$ 1.90 $\mu\text{g}/\text{m}^3$ 0.48 $\mu\text{g}/\text{m}^3$	$\leq 5\mu\text{g}/\text{m}^3$
Highest resulting uncertainty estimate comparison against data quality objective (Measurement Uncertainty)	34.2%	WCM \leq Wd _{qo} Measurement uncertainty defined as 50% for indicative instruments
Maintenance Interval	>Two weeks Note 2	>Two weeks

Note 1: Only one Reference Method was used during the testing of the EDTPM10M. 0.51 $\mu\text{g}/\text{m}^3$ was calculated during operation of two identical Reference Methods during 2014.

Note 2: During the 3 months of operation no maintenance was required. The manufacturer recommends the monitoring system is serviced annually

Certificate No : Sira MC160316/02
This Certificate issued : 19 December 2018

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Description

The Environmental DustTrak™ Aerosol Monitor (TSI Model 854201-M1 or EDTPM10M) includes a data-logging, single- channel 90° light-scattering laser photometer (8542-M) that gives real-time aerosol mass readings. It uses a sheath air system that isolates the aerosol in the optics chamber to keep the optics clean for improved reliability and low maintenance.

The 854201-M1 or EDTPM10M includes automatic zeroing which minimizes the effect of zero drift. The monitor measures size-segregated mass fraction concentrations corresponding to PM 10. Each unit includes an environmental enclosure, a DustTrak photometer, Omni directional inlet with water trap, a heated inlet sample conditioner to reduce humidity effects and a PM10 impactor.

General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule V02 for certificate No. Sira MC160316/02
2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.
4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No : Sira MC160316/02
This Certificate issued : 19 December 2018

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*